

NIBE ERS 30-600



Α

55 dB **◄**))) 665 m³/h



ENERGIA · EHEPГИЯ · ENEPГЕIA · ENERGIJA · ENERGY · ENERGIE · ENERGI 2016 1254/2014



Technical Product Fiche

| Suppliers name | NIBE |
|--|--|
| Model identification | ERS 30-600 |
| Specific energy consumption SEC | SECcold: -71,6; SECaverage: -35,6; SECwarm: -12,3 |
| kWh/(m2*a) for: cold, average, warm | |
| climates | |
| RVU/NRVU/Unidirectional / | RVU - Bidirectional |
| Bidirectional | |
| Type of drive installed | EC motor with 0-100 % modulation range |
| Type of heat recovery (recuperative, | Recuperative |
| regenerative, non) | |
| Thermal efficiency of heat recovery % | 79 |
| Maximum airflow (m ³ /h) | 655 |
| Electric Power input of fan drive at | 340 |
| maximum airflow - W | |
| Sound Power level (Lwa) at reference | 55 |
| airflow Lwa | |
| Reference airflow rate (m³/s) | 0,127 |
| Reference pressure difference (min. | 50 |
| 50Pa) – (Pa) | |
| Specific power input at reference | 0,32 |
| airflow – SEL/SPI (W/ m³/h) | |
| Control factor | 0,85 (with HTS40) |
| Declared maximum internal and | Internal: 2,7% ; External: 1,8% |
| external leakage rates (%) | |
| Mixing rate of non ducted bidirectional | Not applicable |
| ventilation units | |
| Position and description of visual filter | After a specific time the display will tell that it is time to |
| warning | clean the filters or replace them with new ones. |
| Instructions for installing | Not applicable |
| supply/exhaust grilles i facade for | |
| unidirectional devices | |
| Internet adress for pre-/disassembly | www.nibe.eu (manual) |
| instructions | Net conficely |
| Sensitivity for pressure variation for | Not applicable |
| units without ducts + and - 20Pa | Not applied blo |
| For non ducted units - the | Not applicable |
| indoor/outdoor air tightness in (m³/h) | AFCcold=974 - AFCcoverage=227 - AFCcoverage=202 |
| The annual electricity consumption AEC per 100 m ² (kWh electricity /a) for | AECcold=874 ; AECaverage=337 ; AECwarm=292 |
| climates : Average, Warm, Cold | |
| The annual heating saved AHS in | AHScold=8474; AHSaverage=4332 AHSwarm=1959 |
| primary energy (kWh prim/a) per 100 | AIISCOIU-04/4, AIISavei age-4552 AIISWallii-1353 |
| m² for climates : Average, Warm, Cold | |
| iii ioi ciiiiates . Average, Wallii, Colo | |